



30909

Gas Safety Record



Certificate Number	Job Ref	21833	Address : Unit 1-2, 403 Broad Lane														
3689	Eng. Name	Jack Williams	Coventry CV5 7AX +44 02477170800														
Company Gas safe No : 30909	Gas Safe ID No	6016603															
	Work Carried out Date	07/07/26															
	Next Service due Date	07/07/27															
Site Address : . CC04 4 Cryfield Cottage Gibbet Hill Road CV4 7AL			Is the Job Complete										Yes				
			Unsafe situation identified (classification)										No				
Sheet	1	of	3	Has a Warning notice been issued													
				Warning notice number													
				Has the appliance been labelled													
Have you completed all risk assessments : Yes				Has the responsible person been informed													
How many appliances have been tested								Two									
Appliance No.		No 1		No 2		No 3		No 4		No 5		No 6		No 7		No 8	
Make		Worcester 2000		Montpellier													
Model		Gc2000iw		MDOG50LW													
Appliance Type		Condensing Boilers		Free Standing													
Ref No		Boiler 1		Cooker													
Location		Kitchen		Kitchen													
Condition		Good		Poor (visual) satisfactory (mechanically)													
Appliance No.		No 5		No 6		No 7		No 8									
Make																	
Model																	
Appliance Type																	
Ref No																	
Location																	
Condition																	
Appliance No	No1	No2	No3	No4	No5	No6	No7	No8									
Flue Type	Room sealed type C	Flueless															
Flue flow satisfactory	N/A	N/A															
Spillage test satisfactory	N/A	N/A															
Termination satisfactory	Yes	N/A															
Visual condition of flue satisfactory	Yes	N/A															
Flame proving satisfactory	Yes	Yes															
Burner lock out time (seconds)	2	12															
Temp t/stat operation satisfactory	Yes	Yes															
Ventilation Type	N/A	Openable doors and windows															
Mechanical vent / flue interlock satisfactory	N/A	N/A															
Reqd Ventilation low level (cm²)	N/A	N/A															
Reqd Ventilation High level (cm²)	N/A	N/A															
Badged Rating (kW Nett)	20.7	12.2															
Actual Ventilation low level (cm²)	N/A	N/A															
Actual Ventilation High level (cm²)	N/A	N/A															
Ventilation Satisfactory	N/A	Yes															
Firing Mode	Low	High	Low	High	Low	High	Low	High	Low	High	Low	High	Low	High	Low	High	
Heat input rating kW	N/A	N/A	N/A	N/A													
Gas Burner Pressure	N/A	N/A	N/A	N/A													
Gas Flow Rate m³/hr.	N/A	N/A	N/A	N/A													
Ambient (Room) Temperature (°C)	23.9	23.8	N/A	N/A													
Flue Gas Temperature (°C)	36.0	46.7	N/A	N/A													
CO/CO² Ratio	0.0001	0.0007	N/A	N/A													
Oxygen (O²)%	5.6	4.2	N/A	N/A													
Carbon Monoxide (CO) ppm	6	70	N/A	N/A													
Carbon Dioxide (CO²)%	8.72	9.52	N/A	N/A													
Excess Air	36.5	24.9	N/A	N/A													
Gross Efficiency	89.4	88.9	N/A	N/A													
Is the appliance safe to use	Yes		Yes														

Gas Tightness Test									
Gas tightness test carried out (Yes / No)	Yes	Total Installation volume (m³)	0.0022	Max allowable pressure drop (mbar)	1	Type of gauge used (water / electronic)	Electric	Tightness test result (Pass / Fail)	
Where was the Test carried out from?	ECV	Let by test duration (mins)	1	Volume smallest occupied space (m³)	N/A	Smell of gas	N/A	Pass	
Scope of work (e.g. IGE/UP/1 or 1A or 1B)	IGE/UP/1B	Stabilisation period (mins)	1	Tightness test pressure (TTP) (mbar)	21.75	CO Alarm			
						CO Alarm Installed	Date Of Expiry	CO Pass/Fail	
Installation (New / Existing / Extension)	Existing	Tightness test duration (mins)	2	Actual pressure drop (mbar)	0	Yes	04/2035	Pass	
Meter Information									
Gas Meter Present	Yes	Meter room secure	N/A	Meter room key labelled	N/A	Standing pressure (mbar)		Working pressure at Appliances (mbar)	
Meter size	U6	Meter accessible	Yes	Meter room ventilated	N/A	Working pressure at meter	20.98	17.22	
ECV labelled	Yes	Does ECV operate easily	Yes	Adequate gas isolation	Yes	Suitably sleeved Area Adjacent Meter	Yes	Meter Labelling Correct	
Pipework colour coded /identified from point of Test	Yes	Line diagram at meter (current)	N/A	Clear of combustibles	N/A	Installation cross bonded	Yes	N/A	
Gas pipe supported (Where Visible) from point of Test	Yes	Meter Location	Outside meter box		Flue Dilution (CO₂) %	N/A	Air Sample (CO₂) %	N/A	
Manometer Make	Testo	Serial No	26884240	Analyser Make	Testo	Serial No	61857248		
Description of work: Boiler service, co device check and hob service									
Defects					Remedial work required				
No 1	Tin foil on cooker				Removed tin foil				
No 2									
No 3									
No 4									
No 5									
No 6									
No 7									
No 8									
Parts used			Part Number		Qty		Declaration of Gas safety: I confirm that all of the work described on this form has been satisfactorily completed in accordance with the current Gas Safety (Installation & Use) regulations, industry standards and procedures.		
Print Name	Jack Williams		Engineer's Signature						
The work has been carried out to my satisfaction. I agree to pay for all chargeable work carried out and the cost of any parts ordered and/or supplied.									
Print Name	No person present		Customer Signature						

Tightness Test Carried out from this Valve 'Label'




General information			
Customer		Name of measurement program	Tightness test
4 Cryfield Cottage		Date of measurement	07/07/2026 11:08:55
Instrument information			
Instrument name/Serial number		Measurement parameters	
testo 510 (46527985)		Differential pressure	
Measurement parameters			
Measuring mode	Timed	Maximum pressure drop	1.00 mbar
Measuring cycle	20 sec	Pressure start (P Start)	21.75 mbar
Use stabilisation time	Yes	Measurement result	Passed
Measurement duration (target)	2 min 0 sec	Start time	07/07/2026 11:06:11
Pressure probe	testo 510 (46527985)	End	07/07/2026 11:08:11
Fuel type	Natural gas	Duration	2 min 0 sec
Measurement			
Maximum pressure drop		1.00 mbar	
Final pressure drop		1.27 mbar	
Date/Time	ΔP current [mbar]	985 [mbar]	
07/07/2026 11:06:11		21.75	
07/07/2026 11:06:31	0.24	21.99	
07/07/2026 11:06:51	0.48	22.23	
07/07/2026 11:07:11	0.68	22.43	
07/07/2026 11:07:31	0.89	22.64	
07/07/2026 11:07:51	1.09	22.84	
07/07/2026 11:08:11	1.27	23.02	



Appliance Flue Termination



Warning Label 'if Applicable'



CO Expiry Date



Location of CO



Photo of Unsafe Situation	Defect 1	Defect 2
		
Defect 3	Defect 4	Defect 5
Defect 6	Defect 7	Defect 8