


Gas Tightness Test									
Gas tightness test carried out (Yes / No)	Yes	Total Installation volume (m³)	0N/A	Max allowable pressure drop (mbar)	2	Type of gauge used (water / electronic)	Electric	Tightness test result (Pass / Fail)	
Where was the Test carried out from?	ECV	Let by test duration (mins)	0	Volume smallest occupied space (m³)	0N/A	Smell of gas	N/A	Pass	
Scope of work (e.g. IGE/UP/1 or 1A or 1B)	IGE/UP/1B	Stabilisation period (mins)	1	Tightness test pressure (TTP) (mbar)	20	CO Alarm			
						CO Alarm Installed	Date Of Expiry	CO Pass/Fail	
Installation (New / Existing / Extension)	Existing	Tightness test duration (mins)	1	Actual pressure drop (mbar)	0	Yes	09/2025	Pass	
Meter Information									
Meter Location	Externally next front door	Meter room secure	No lock seized unable to lock	Meter room key labelled	Square T bar	Standing pressure at meter (mbar)	22	Working pressure at Appliances (mbar)	
Meter size	U6	Meter accessible	Yes	Meter room ventilated	Yes	Working pressure at meter	18	20	
ECV labelled	Yes	Does ECV operate easily	Yes	Adequate gas isolation	Yes	Suitably sleeved Area Adjacent Meter	Yes	Meter Labelling Correct	
Pipework colour coded /identified from point of Test	Concealed	Line diagram at meter (current)	N/a	Clear of combustibles	Yes	Installation cross bonded	Yes	Yes	
Gas pipe supported (Where Visible) from point of Test	Concealed				Flue Dilution (CO ₂) %	N/a	Air Sample (CO ₂) %	N/a	
Manometer Make	Testo	Serial No	N/a	Analyser Make	Testo	Serial No	61857248		
Description of work: Tightness test, boiler service and co alarm tested									
Defects					Remedial work required				
No 1	Gas meter door lock seized unable to lock				Lock needs repairing or replacing				
No 2	Not enough clearance to get boiler case off easily				More of the kitchen unit needs removing so case can be easily removed				
No 3									
No 4									
No 5									
No 6									
No 7									
No 8									
Parts used			Part Number		Qty		Declaration of Gas safety: I confirm that all of the work described on this form has been satisfactorily completed in accordance with the current Gas Safety (Installation & Use) regulations, industry standards and procedures.		
Print Name	Sean Moloney		Engineer's Signature						
The work has been carried out to my satisfaction. I agree to pay for all chargeable work carried out and the cost of any parts ordered and/or supplied.									
Print Name	No person present		Customer Signature						

Tightness Test Carried out from this Valve 'Label'



Appliance Flue Termination




Warning Label 'if Applicable'

CO Expiry Date

Location of CO Alarm



Photo of Unsafe Situation	Defect 1	Defect 2
	 A close-up photograph showing a metal fastener, possibly a bolt or nut, protruding from a wooden surface. The wood appears to be part of a structure, possibly a railing or a piece of furniture, and the fastener is not properly secured or is in a hazardous position.	 A photograph showing the interior of a white cabinet or enclosure. The cabinet is open, revealing internal components and wiring. There are some labels and markings on the inside of the cabinet doors, and the overall appearance suggests a piece of equipment that may not be properly maintained or secured.
Defect 3	Defect 4	Defect 5
Defect 6	Defect 7	Defect 8