



**Gas Tightness Test**

Gas tightness test carried out (Yes / No)	Yes	Total Installation volume (m³)	0.0028	Max allowable pressure drop (mbar)	4	Type of gauge used (water / electronic)	Electric	Tightness test result (Pass / Fail)	
Where was the Test carried out from?	ECV	Let by test duration (mins)	1	Volume smallest occupied space (m³)	N/A	Smell of gas	N/A	Pass	
Scope of work (e.g. IGE/UP/1 or 1A or 1B)	IGE/UP/1B	Stabilisation period (mins)	1	Tightness test pressure (TTP) (mbar)	18.37	CO Alarm			
						CO Alarm Installed	Date Of Expiry	CO Pass/Fail	
Installation (New / Existing / Extension)	Existing	Tightness test duration (mins)	2	Actual pressure drop (mbar)	0	Yes	09/2035		


**Meter Information**

Gas Meter Present	Yes	Meter room secure	N/A	Meter room key labelled	N/A	Standing pressure (mbar)		Working pressure at Appliances (mbar)	
Meter size	U6	Meter accessible	Yes	Meter room ventilated	N/A	Working pressure at meter	20.34		18.02
ECV labelled	Yes	Does ECV operate easily	Yes	Adequate gas isolation	Yes	Suitably sleeved Area Adjacent Meter	Yes	Meter Labelling Correct	
Pipework colour coded /identified from point of Test	Yes	Line diagram at meter (current)	N/A	Clear of combustibles	Yes	Installation cross bonded	Yes	Yes	Yes
Gas pipe supported (Where Visible) from point of Test	Yes	Meter Location	Meter box outside		Flue Dilution (CO <sub>2</sub> ) %	N/A	Air Sample (CO <sub>2</sub> ) %	N/A	
Manometer Make	Testo	Serial No	26884240	Analyser Make	Testo	Serial No	61857248		

Description of work: Boiler service co device check and cp12

Defects		Remedial work required	
No 1			
No 2			
No 3			
No 4			
No 5			
No 6			
No 7			
No 8			

Parts used	Part Number	Qty	Declaration of Gas safety: I confirm that all of the work described on this form has been satisfactorily completed in accordance with the current Gas Safety (Installation & Use) regulations, industry standards and procedures.

Print Name	Jack Williams	Engineer's Signature	
------------	---------------	----------------------	---

The work has been carried out to my satisfaction. I agree to pay for all chargeable work carried out and the cost of any parts ordered and/or supplied.

Print Name	No person present	Customer Signature	
------------	-------------------	--------------------	--

## Tightness Test Carried out from this Valve 'Label'

### Measurement protocol

**General information**

<b>Customer</b> 59 Heronbank Staff Flat	<b>Name of measurement program</b> Tightness test	<b>Date of measurement</b> 12/02/2026 9:28:57
--	--	--

**Instrument information**

<b>Instrument name/Serial number</b> Isto 510 (46884240)	<b>Measurement parameters</b> Differential pressure
---	--

**Measurement parameters**

<b>Measuring mode</b> Timed	<b>Maximum pressure drop</b> 4.00 mbar
<b>Measuring cycle</b> 20 sec	<b>Pressure start (P Start)</b> 18.37 mbar
<b>Use stabilisation time</b> Yes	<b>Measurement result</b> Passed
<b>Measurement duration (target)</b> 2 min 0 sec	<b>Start time</b> 12/02/2026 9:28:19
<b>Pressure probe</b> Isto 510 (46884240)	<b>End</b> 12/02/2026 9:30:19
<b>Fuel type</b> Natural gas	<b>Duration</b> 2 min 0 sec

**Measurement**

<b>Maximum pressure drop</b>	4.00 mbar
<b>Final pressure drop</b>	1.41 mbar

Date/Time	dP0 [mbar]	dP current [mbar]
12/02/2026 9:28:19	18.37	
12/02/2026 9:28:29	18.88	0.51
12/02/2026 9:28:59	18.94	0.57
12/02/2026 9:29:19	19.18	0.81
12/02/2026 9:29:39	19.40	1.03
12/02/2026 9:29:59	19.89	1.22
12/02/2026 9:30:19	19.78	1.41



## Appliance Flue Termination



### Warning Label 'if Applicable'

### CO Expiry Date

### Location of CO Alarm



Photo of Unsafe Situation	Defect 1	Defect 2
Defect 3	Defect 4	Defect 5
Defect 6	Defect 7	Defect 8