




Gas Tightness Test									
Gas tightness test carried out (Yes / No)	Yes	Total Installation volume (m <sup>3</sup> )		Max allowable pressure drop (mbar)	4	Type of gauge used (water / electronic)	Electric	Tightness test result (Pass / Fail)	
Where was the Test carried out from?	ECV	Let by test duration (mins)	1	Volume smallest occupied space (m <sup>3</sup> )		Smell of gas	N/A	Pass	
Scope of work (e.g. IGE/UP/1 or 1A or 1B)	IGE/UP/1B	Stabilisation period (mins)	1	Tightness test pressure (TTP) (mbar)	19.92	CO Alarm			
						CO Alarm Installed	Date Of Expiry	CO Pass/Fail	
Installation (New / Existing / Extension)	Existing	Tightness test duration (mins)	2	Actual pressure drop (mbar)	0	Yes	06/2035	Pass	
Meter Information									
Gas Meter Present	Yes	Meter room secure	N/A	Meter room key labelled	N/A	Standing pressure (mbar)	27.99	Working pressure at Appliances (mbar)	
Meter size	U6	Meter accessible	Yes	Meter room ventilated	N/A	Working pressure at meter	21.50	18.87	
ECV labelled	Yes	Does ECV operate easily	Yes	Adequate gas isolation	Yes	Suitably sleeved Area Adjacent Meter	Yes	Meter Labelling Correct	
Pipework colour coded /identified from point of Test	Yes	Line diagram at meter (current)	N/A	Clear of combustibles	N/A	Installation cross bonded	Yes	Yes	
Gas pipe supported (Where Visible) from point of Test	Yes	Meter Location	Outside meter box		Flue Dilution (CO <sub>2</sub> ) %	N/A	Air Sample (CO <sub>2</sub> ) %	N/A	
Manometer Make	Testo	Serial No	26884240		Analyser Make	Testo	Serial No	61857248	
Description of work: Boiler service and co device check									
Defects					Remedial work required				
No 1	Broken LH clip on compact boiler				Replaced clip				
No 2	Co alarm nearly out of date				Replaced co alarm				
No 3									
No 4									
No 5									
No 6									
No 7									
No 8									
Parts used			Part Number		Qty		Declaration of Gas safety: I confirm that all of the work described on this form has been satisfactorily completed in accordance with the current Gas Safety (Installation & Use) regulations, industry standards and procedures.		
Left hand			Worcester compact clip		1				
Honeywell carbon monoxide alarm			RC200-1		1				
Print Name	Jack Williams		Engineer's Signature						
The work has been carried out to my satisfaction. I agree to pay for all chargeable work carried out and the cost of any parts ordered and/or supplied.									
Print Name	No person present		Customer Signature						

## Tightness Test Carried out from this Valve 'Label'

Customer: 19 Lakeside Staff Flat  
 Name of measurement program: Tightness test  
 Date of measurement: 14/05/2025 14:11:30

**Instrument information**

Instrument name/Serial number: testo 510 (46884240)  
 Measurement parameters: Differential pressure

**Measurement parameters**

Measuring mode: Timed  
 Measuring cycle: 20 sec  
 Use stabilisation time: Yes  
 Measurement duration (Range): 2 min 0 sec  
 Pressure probe: testo 510 (46884240)  
 Fuel type: Natural gas

Maximum pressure drop: 4.10 mbar  
 Pressure start (P Start): 10.92 mbar  
 Measurement result: Passed  
 Start time: 14/05/2025 14:08:36  
 End time: 14/05/2025 14:10:36  
 Duration: 2 min 0 sec

Measurement:  
 Maximum pressure drop: 4.10 mbar  
 Final pressure drop: 0.79 mbar

Date/Time	240 [mbar]	ΔP current [mbar]
14/05/2025 14:08:36	11.92	0.00
14/05/2025 14:08:56	20.04	0.12
14/05/2025 14:09:16	20.22	0.30
14/05/2025 14:09:36	20.31	0.39
14/05/2025 14:09:56	20.43	0.51
14/05/2025 14:10:16	20.51	0.59
14/05/2025 14:10:36	20.71	0.79



## Appliance Flue Termination





## Warning Label 'if Applicable'

## CO Expiry Date

## Location of CO Alarm



Photo of Unsafe Situation	Defect 1	Defect 2
		
Defect 3	Defect 4	Defect 5
Defect 6	Defect 7	Defect 8