




Gas Tightness Test									
Gas tightness test carried out (Yes / No)	Yes	Total Installation volume (m <sup>3</sup> )		Max allowable pressure drop (mbar)	4	Type of gauge used (water / electronic)	Electric	Tightness test result (Pass / Fail)	
Where was the Test carried out from?	ECV	Let by test duration (mins)	1	Volume smallest occupied space (m <sup>3</sup> )		Smell of gas	N/A	Pass	
Scope of work (e.g. IGE/UP/1 or 1A or 1B)	IGE/UP/1B	Stabilisation period (mins)	1	Tightness test pressure (TTP) (mbar)	21.13	CO Alarm			
						CO Alarm Installed	Date Of Expiry	CO Pass/Fail	
Installation (New / Existing / Extension)	Existing	Tightness test duration (mins)	2	Actual pressure drop (mbar)	0	Yes	07/2033	Pass	
Meter Information									
Gas Meter Present	Yes	Meter room secure	N/A	Meter room key labelled	N/A	Standing pressure (mbar)		Working pressure at Appliances (mbar)	
Meter size	U6	Meter accessible	Yes	Meter room ventilated	N/A	Working pressure at meter	21.78	20.30	
ECV labelled	Yes	Does ECV operate easily	Yes	Adequate gas isolation	Yes	Suitably sleeved Area Adjacent Meter	Yes	Meter Labelling Correct	
Pipework colour coded /identified from point of Test	Yes	Line diagram at meter (current)	N/A	Clear of combustibles	N/A	Installation cross bonded	Yes	Yes	
Gas pipe supported (Where Visible) from point of Test	Yes	Meter Location	Outside meter box		Flue Dilution (CO <sub>2</sub> ) %	N/A	Air Sample (CO <sub>2</sub> ) %	N/A	
Manometer Make	Testo	Serial No	26884240	Analyser Make	Testo	Serial No	Tes		
Description of work: Boiler service and co device check									
Defects					Remedial work required				
No 1	Broken meter box				Replace lid				
No 2									
No 3									
No 4									
No 5									
No 6									
No 7									
No 8									
Parts used			Part Number		Qty		Declaration of Gas safety: I confirm that all of the work described on this form has been satisfactorily completed in accordance with the current Gas Safety (Installation & Use) regulations, industry standards and procedures.		
Print Name	Jack Williams		Engineer's Signature						
The work has been carried out to my satisfaction. I agree to pay for all chargeable work carried out and the cost of any parts ordered and/or supplied.									
Print Name	No person present		Customer Signature						

## Tightness Test Carried out from this Valve 'Label'



### Measurement protocol

General information		Name of measurement program	Tightness test
Customer	30 Lakeside Staff Flat	Date of measurement	04/06/2025 10:46:55
Instrument information			
Instrument name/serial number	Measurement parameters		
testo 510 (46884240)	Differential pressure		
Measurement parameters			
Measuring mode	Timed	Maximum pressure drop	4.10 mbar
Measuring cable	20 sec	Pressure start (P_start)	21.13 mbar
Line stabilisation time	Yes	Measurement result	Passed
Measurement duration	2 min 0 sec	Start time	04/06/2025 10:44:53
Ring ID		End	04/06/2025 10:46:53
Pressure probe	testo 510 (46884240)	Duration	2 min 0 sec
Fuel type	Natural gas		
Measurement			
Maximum pressure drop	4.10 mbar		
Final pressure drop	0.79 mbar		
Date/Time	P48 [mbar]	AP [mbar]	
04/06/2025 10:44:53	21.13		
04/06/2025 10:45:19	21.31	0.10	
04/06/2025 10:45:33	21.38	0.26	
04/06/2025 10:45:53	21.43	0.30	
04/06/2025 10:46:13	21.60	0.47	
04/06/2025 10:46:33	21.76	0.63	
04/06/2025 10:46:53	21.92	0.79	

## Appliance Flue Termination




### Warning Label 'if Applicable'

### CO Expiry Date

### Location of CO Alarm



Photo of Unsafe Situation	Defect 1	Defect 2
		
Defect 3	Defect 4	Defect 5
Defect 6	Defect 7	Defect 8