




Gas Tightness Test									
Gas tightness test carried out (Yes / No)	Yes	Total Installation volume (m³)		Max allowable pressure drop (mbar)	4.1	Type of gauge used (water / electronic)		Tightness test result (Pass / Fail)	
Where was the Test carried out from?	ECV	Let by test duration (mins)	1	Volume smallest occupied space (m³)		Smell of gas	N/A		
Scope of work (e.g. IGE/UP/1 or 1A or 1B)	IGE/UP/1B	Stabilisation period (mins)	1	Tightness test pressure (TTP) (mbar)	21.38	CO Alarm			
						CO Alarm Installed	Date Of Expiry	CO Pass/Fail	
Installation (New / Existing / Extension)	Existing	Tightness test duration (mins)	2	Actual pressure drop (mbar)	0	Yes	07/2035	Pass	
Meter Information									
Gas Meter Present	Yes	Meter room secure	N/A	Meter room key labelled	N/A	Standing pressure (mbar)		Working pressure at Appliances (mbar)	
Meter size	U6	Meter accessible	Yes	Meter room ventilated	N/A	Working pressure at meter	21.45	18.82	
ECV labelled	Yes	Does ECV operate easily	Yes	Adequate gas isolation	Yes	Suitably sleeved Area Adjacent Meter	Yes	Meter Labelling Correct	
Pipework colour coded /identified from point of Test	Yes	Line diagram at meter (current)	N/A	Clear of combustibles	Yes	Installation cross bonded	Yes	Yes	
Gas pipe supported (Where Visible) from point of Test	Yes	Meter Location	Outside mete box		Flue Dilution (CO <sub>2</sub> ) %	N/A	Air Sample (CO <sub>2</sub> ) %	N/A	
Manometer Make	Testo	Serial No	26884240	Analyser Make	Testo	Serial No	61857248		
Description of work: Boiler service and co2 device check. Tightness test passed but on the sheet you can see a 1.2mb rise. This was due to fluctuation and not a passing ECV. I have sprayed the barrel and all ok.									
Defects					Remedial work required				
No 1	Standing pressure was at 70mb				Adjusted govner now ok				
No 2									
No 3									
No 4									
No 5									
No 6									
No 7									
No 8									
Parts used			Part Number		Qty		Declaration of Gas safety: I confirm that all of the work described on this form has been satisfactorily completed in accordance with the current Gas Safety (Installation & Use) regulations, industry standards and procedures.		
			Co alarm		1				
			Carbon monoxide alarm						
Print Name	Jack Williams		Engineer's Signature						
The work has been carried out to my satisfaction. I agree to pay for all chargeable work carried out and the cost of any parts ordered and/or supplied.									
Print Name	No person present		Customer Signature						

## Tightness Test Carried out from this Valve 'Label'

### Measurement protocol

**Customer:** 36 Lakeside Strat Flat  
**Status of measurement program:** Tightness test  
**Date of measurement:** 23/05/2025 11:24:34

**Instrument name/Serial number:** Neuko S10i (45884240)  
**Measurement parameters:** Differential pressure

**Measurement parameters:**

Measuring mode	Timed	Maximum pressure drop	4.10 mbar
Measuring cycle	20 sec	Pressure start (P_start)	21.38 mbar
Use stabilisation time	Yes	Measurement result	Passed
Measurement duration	2 min 0 sec	Start time	23/05/2025 11:22:21
Pressure probe	Neuko S10i (45884240)	End	23/05/2025 11:24:21
Fuel type	Natural gas	Duration	2 min 0 sec

Date/Time	ΔP0 [mbar]	ΔP current [mbar]
23/05/2025 11:22:21	21.38	0.32
23/05/2025 11:22:41	21.32	0.40
23/05/2025 11:23:01	21.38	0.37
23/05/2025 11:23:21	21.32	0.30
23/05/2025 11:23:41	21.38	0.34
23/05/2025 11:24:01	21.32	0.34
23/05/2025 11:24:21	21.32	0.34



## Appliance Flue Termination




## Warning Label 'if Applicable'

## CO Expiry Date

## Location of CO Alarm



Photo of Unsafe Situation	Defect 1	Defect 2
	 <p>The image shows a digital pressure gauge interface. At the top left, it says "testo 510i - 240". In the center, there is a circular gauge with a needle pointing to the value "70.18 mbar". Below the gauge, the scale is marked with "0.00" on the left and "20.0" on the right. The gauge is set against a light gray background with a white border.</p>	
Defect 3	Defect 4	Defect 5
Defect 6	Defect 7	Defect 8