

Gas Tightness Test

Gas tightness test carried out (Yes / No)	Yes	Total Installation volume (m³)		Max allowable pressure drop (mbar)	4.1	Type of gauge used (water / electronic)		Tightness test result (Pass / Fail)	
Where was the Test carried out from?	ECV	Let by test duration (mins)	1	Volume smallest occupied space (m³)		Smell of gas	N/A		
Scope of work (e.g. IGE/UP/1 or 1A or 1B)	IGE/UP/1B	Stabilisation period (mins)	1	Tightness test pressure (TTP) (mbar)	21.47	CO Alarm			
						CO Alarm Installed	Date Of Expiry	CO Pass/Fail	
Installation (New / Existing / Extension)		Tightness test duration (mins)	2	Actual pressure drop (mbar)		Yes	07/2033	Pass	

Meter Information

Gas Meter Present	Yes	Meter room secure	N/A	Meter room key labelled	N/A	Standing pressure (mbar)		Working pressure at Appliances (mbar)	
Meter size	U6	Meter accessible	Yes	Meter room ventilated	N/A	Working pressure at meter	21.34		19.60
ECV labelled	Yes	Does ECV operate easily	Yes	Adequate gas isolation	Yes	Suitably sleeved Area Adjacent Meter	Yes	Meter Labelling Correct	
Pipework colour coded /identified from point of Test	Yes	Line diagram at meter (current)	N/A	Clear of combustibles	Yes	Installation cross bonded	Yes	Yes	Yes
Gas pipe supported (Where Visible) from point of Test	Yes	Meter Location	Outside meter box		Flue Dilution (CO ₂) %	N/A	Air Sample (CO ₂) %	N/A	

Manometer Make	Testo	Serial No	26884240	Analyser Make	Testo	Serial No	61857248
----------------	-------	-----------	----------	---------------	-------	-----------	----------

Description of work: Boiler service and co2 device check device check

Defects		Remedial work required	
No 1			
No 2			
No 3			
No 4			
No 5			
No 6			
No 7			
No 8			

Parts used	Part Number	Qty	Declaration of Gas safety: I confirm that all of the work described on this form has been satisfactorily completed in accordance with the current Gas Safety (Installation & Use) regulations, industry standards and procedures.

Print Name	Jack Williams	Engineer's Signature	
------------	---------------	----------------------	---

The work has been carried out to my satisfaction. I agree to pay for all chargeable work carried out and the cost of any parts ordered and/or supplied.

Print Name	No person present	Customer Signature	
------------	-------------------	--------------------	--

Tightness Test Carried out from this Valve 'Label'

Measurement protocol

Customer information

Customer	Name of measurement program	Tightness test
38 Lakside staff flat	Date of measurement	23/05/2025 10:49:13

Instrument information

Instrument name/Serial number	Measurement parameters
Isoto 510 (45984240)	Differential pressure

Measurement parameters

Measuring mode	Timed	Maximum pressure drop	4.10 mbar
Measuring cycle	20 sec	Pressure start (P_start)	21.44 mbar
Use calibration seal	Yes	Measurement result	Passed
Measurement duration	2 min 0 sec	Start time	23/05/2025 10:46:17
Pressure probe	Isoto 510 (45984240)	End	23/05/2025 10:48:17
Fuel type	Natural gas	Duration	2 min 0 sec

Measurement

Maximum pressure drop	4.10 mbar
Final pressure drop	0.21 mbar

Date/Time	d40 (mbar)	dP current (mbar)
23/05/2025 10:46:17	21.44	0.05
23/05/2025 10:46:37	21.45	0.10
23/05/2025 10:46:57	21.45	0.08
23/05/2025 10:47:17	21.70	0.05
23/05/2025 10:47:37	21.70	0.05
23/05/2025 10:47:57	21.68	0.24
23/05/2025 10:48:17	21.69	0.21



Appliance Flue Termination



Warning Label 'if Applicable'

CO Expiry Date

Location of CO Alarm



Photo of Unsafe Situation	Defect 1	Defect 2
Defect 3	Defect 4	Defect 5
Defect 6	Defect 7	Defect 8