


Gas Tightness Test									
Gas tightness test carried out (Yes / No)	Yes	Total Installation volume (m ³)		Max allowable pressure drop (mbar)	4	Type of gauge used (water / electronic)	Electric	Tightness test result (Pass / Fail)	
Where was the Test carried out from?	ECV	Let by test duration (mins)	1	Volume smallest occupied space (m ³)		Smell of gas	N/A	Pass	
Scope of work (e.g. IGE/UP/1 or 1A or 1B)	IGE/UP/1B	Stabilisation period (mins)	1	Tightness test pressure (TTP) (mbar)	20.76	CO Alarm			
						CO Alarm Installed	Date Of Expiry	CO Pass/Fail	
Installation (New / Existing / Extension)	Existing	Tightness test duration (mins)	2	Actual pressure drop (mbar)	0.36	Yes	07/2033	Pass	
Meter Information									
Gas Meter Present	Yes	Meter room secure	N/A	Meter room key labelled	N/A	Standing pressure (mbar)		Working pressure at Appliances (mbar)	
Meter size	U6	Meter accessible	Yes	Meter room ventilated	N/A	Working pressure at meter	20.56	19.06	
ECV labelled	Yes	Does ECV operate easily	Yes	Adequate gas isolation	Yes	Suitably sleeved Area Adjacent Meter	Yes	Meter Labelling Correct	
Pipework colour coded /identified from point of Test	Yes	Line diagram at meter (current)	N/A	Clear of combustibles	N/A	Installation cross bonded	Yes	Yes	
Gas pipe supported (Where Visible) from point of Test	Yes	Meter Location	Outside meter box		Flue Dilution (CO ₂) %	N/A	Air Sample (CO ₂) %	N/A	
Manometer Make	Testo	Serial No	26884240	Analyser Make	Testo	Serial No	61857248		
Description of work: Boiler service and co device check.									
Defects					Remedial work required				
No 1	Plume kit incorrectly installed				Install new flue piece and new plume kit correctly				
No 2									
No 3									
No 4									
No 5									
No 6									
No 7									
No 8									
Parts used			Part Number		Qty		Declaration of Gas safety: I confirm that all of the work described on this form has been satisfactorily completed in accordance with the current Gas Safety (Installation & Use) regulations, industry standards and procedures.		
Print Name	Jack Williams		Engineer's Signature						
The work has been carried out to my satisfaction. I agree to pay for all chargeable work carried out and the cost of any parts ordered and/or supplied.									
Print Name	No person present		Customer Signature						

Tightness Test Carried out from this Valve 'Label'



Measurement protocol

Customer information		Name of measurement program	
Customer	-45 Labrador Staff Flat	Program	Tightness test
Date of measurement		Date of measurement	04/06/2025 9:55:47
Measurement information		Measurement parameters	
Measurement name/Serial number	Serial 9191 (450884240)	Differential pressure	
Measurement parameters			
Measuring mode	Turned	Maximum pressure drop	-4.10 mbar
Measuring range	200 mm	Pressure start (if start)	200.70 mbar
Flow calibration type	Yes	Measurement result	Pass
Measurement duration	3 min 0 sec	Start time	04/06/2025 9:55:44
Pressure probe	Model 9191 (450884240)	Stop	04/06/2025 9:56:44
Flow type	Natural gas	Duration	3 min 0 sec
Measurement results			
Maximum pressure drop		-4.10 mbar	
Final pressure drop		-0.36 mbar	
Data/Time			
04/06/2025 9:55:44	200.70	-0.36	
04/06/2025 9:55:44	200.70	-0.36	
04/06/2025 9:55:44	200.70	-0.36	
04/06/2025 9:55:44	200.70	-0.36	
04/06/2025 9:55:44	200.70	-0.36	
04/06/2025 9:55:44	200.70	-0.36	
04/06/2025 9:55:44	200.70	-0.36	
04/06/2025 9:55:44	200.70	-0.36	
04/06/2025 9:55:44	200.70	-0.36	
04/06/2025 9:55:44	200.70	-0.36	

Appliance Flue Termination




Warning Label 'if Applicable'

CO Expiry Date

Location of CO Alarm



Photo of Unsafe Situation	Defect 1	Defect 2
		
Defect 3	Defect 4	Defect 5
Defect 6	Defect 7	Defect 8