



PRT
HEATING LTD
COMMERCIAL | INDUSTRIAL | DOMESTIC

[illegible]

Gas Tightness Test										
Gas tightness test carried out (Yes / No)	Yes	Total Installation volume (m³)	0.0003		Max allowable pressure drop (mbar)	4		Type of gauge used (water / electronic)	Electric	Tightness test result (Pass / Fail)
Where was the Test carried out from?	ECV	Let by test duration (mins)	1		Volume smallest occupied space (m³)			Smell of gas	N/A	Pass
Scope of work (e.g. IGE/UP/1 or 1A or 1B)	IGE/UP/1B	Stabilisation period (mins)	1		Tightness test pressure (TTP) (mbar)	20		CO Alarm		
								CO Alarm Installed	Date Of Expiry	CO Pass/Fail
Installation (New / Existing / Extension)	Existing	Tightness test duration (mins)	2		Actual pressure drop (mbar)	0		Yes	09/2033	Pass
Meter Information										
Gas Meter Present	Yes	Meter room secure			Meter room key labelled			Standing pressure (mbar)		Working pressure at Appliances (mbar)
Meter size	U7	Meter accessible			Meter room ventilated			Working pressure at meter	19	19
ECV labelled		Does ECV operate easily			Adequate gas isolation			Suitably sleeved Area Adjacent Meter		Meter Labelling Correct
Pipework colour coded /identified from point of Test		Line diagram at meter (current)			Clear of combustibles			Installation cross bonded		
Gas pipe supported (Where Visible) from point of Test		Meter Location	Outside			Flue Dilution (CO₂) %	N/A		Air Sample (CO₂) %	N/A
Manometer Make	Testo	Serial No	46884291		Analyser Make	Testo	Serial No	63228742		
Description of work: Serviced boiler										
Defects					Remedial work required					
No 1										
No 2										
No 3										
No 4										
No 5										
No 6										
No 7										
No 8										
Parts used			Part Number		Qty		Declaration of Gas safety: I confirm that all of the work described on this form has been satisfactorily completed in accordance with the current Gas Safety (Installation & Use) regulations, industry standards and procedures.			
Print Name	Steven Kirby		Engineer's Signature							
The work has been carried out to my satisfaction. I agree to pay for all chargeable work carried out and the cost of any parts ordered and/or supplied.										
Print Name	No person present		Customer Signature							

Tightness Test Carried out from this Valve 'Label'		
		
Appliance Flue Termination		
		
Warning Label 'if Applicable'	CO Expiry Date	Location
		

Photo of Unsafe Situation	Defect 1	Defect 2
Defect 3	Defect 4	Defect 5
Defect 6	Defect 7	Defect 8