



## Sample Labels & Results Records Sheets

**circuIt**  
FAILED ASSETS REPORT Ref: 6510.17  
Client: RHONDDA CYNON TAF COUNTY BOROUGH COUNCIL  
Site: Pontypridd High School 5308/01 Albion Community Campus Clifftydd Pontypridd CF37 4SF

Date:	22/02/2017 11:31:51
Item:	CLASS 2 CHARGER
Location:	GROUND FLOOR
Room / Area:	CLASS 115
Comments:	LEAD DAMAGE



Date:	20/02/2017 10:58:27
Item:	BASE UNIT
Location:	GROUND FLOOR
Room / Area:	CLASS 106
Comments:	ALL VIS AS PER CLIENT REQUEST



Sample Labels & Results Records Sheets

**circuit**  
Specialist Electrical Testing

JobRef: 6510.17  
Date: 20/02/2017  
Client: RHONDDA CYNON TAF COUNTY BOROUGH COUNCIL  
Site: Pontypridd High School/5308/01 Albion Community Campus Citylynydd Pontypridd CF37 4SF

Page 1 of 198 - Items on this page 20 - Items 1 to 20

Equip No	Location	Sub Location	Appliance	Visual	Earth	Class	Fuse	Plug	Insulation	Date	Frequency	E Leak	Load	Pass	Comment
2149312	HAIR BUILDING FIRST FLOOR	STANDARD OFFICE	PENCIL GRABBER	N/A	II				>19.99	08/03/2017	12 MONTHS	<0.10mA	I	F	
2149311	HAIR BUILDING FIRST FLOOR	STANDARD OFFICE	PENCIL GRABBER	N/A	II				>19.99	08/03/2017	12 MONTHS	<0.10mA	I	F	
2149310	HAIR BUILDING FIRST FLOOR	STANDARD OFFICE	MONITOR	0.11	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149309	HAIR BUILDING FIRST FLOOR	STANDARD OFFICE	IEC POWER LEAD	0.07	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149308	HAIR BUILDING FIRST FLOOR	STANDARD OFFICE	EXTENSION LEAD	0.00	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149307	HAIR BUILDING FIRST FLOOR	STANDARD OFFICE	EXTENSION LEAD	0.04	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149306	HAIR BUILDING FIRST FLOOR	STANDARD OFFICE	BASE UNIT	0.08	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149305	HAIR BUILDING FIRST FLOOR	STANDARD OFFICE	IEC POWER LEAD	0.05	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149304	HAIR BUILDING FIRST FLOOR	STANDARD OFFICE	BASE UNIT	0.12	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149303	HAIR BUILDING FIRST FLOOR	STANDARD OFFICE	IEC POWER LEAD	0.08	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149302	HAIR BUILDING FIRST FLOOR	STANDARD OFFICE	MONITOR	0.10	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149301	HAIR BUILDING FIRST FLOOR	STANDARD OFFICE	IEC POWER LEAD	0.07	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149300	HAIR BUILDING FIRST FLOOR	STANDARD OFFICE	MONITOR	0.08	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149299	HAIR BUILDING FIRST FLOOR	STANDARD OFFICE	IEC POWER LEAD	0.06	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149298	HAIR BUILDING FIRST FLOOR	ATTENDANCE OFFICE	MONITOR	N/A	II				>19.99	08/03/2017	12 MONTHS	<0.10mA	I	F	
2149297	HAIR BUILDING FIRST FLOOR	ATTENDANCE OFFICE	POWER SUPPLY UNIT	N/A	II				>19.99	08/03/2017	12 MONTHS	<0.10mA	I	F	
2149296	HAIR BUILDING FIRST FLOOR	ATTENDANCE OFFICE	CLASS 1 LEAD	0.07	I				>19.99	08/03/2017	12 MONTHS	<0.10mA	I	F	
2149295	HAIR BUILDING FIRST FLOOR	ATTENDANCE OFFICE	BASE UNIT	0.09	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149294	HAIR BUILDING FIRST FLOOR	ATTENDANCE OFFICE	IEC POWER LEAD	0.06	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149293	HAIR BUILDING FIRST FLOOR	ATTENDANCE OFFICE	POWER SUPPLY UNIT	N/A	II				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	

**circuit**  
Specialist Electrical Testing

JobRef: 6510.17  
Date: 20/02/2017  
Client: RHONDDA CYNON TAF COUNTY BOROUGH COUNCIL  
Site: Pontypridd High School/5308/01 Albion Community Campus Citylynydd Pontypridd CF37 4SF

Page 2 of 198 - Items on this page 20 - Items 21 to 40

Equip No	Location	Sub Location	Appliance	Visual	Earth	Class	Fuse	Plug	Insulation	Date	Frequency	E Leak	Load	Pass	Comment
2149292	HAIR BUILDING FIRST FLOOR	ATTENDANCE OFFICE	IEC POWER LEAD	0.07	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149291	HAIR BUILDING FIRST FLOOR	ATTENDANCE OFFICE	MONITOR	0.11	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149290	HAIR BUILDING FIRST FLOOR	ATTENDANCE OFFICE	IEC POWER LEAD	0.08	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149289	HAIR BUILDING FIRST FLOOR	ATTENDANCE OFFICE	BASE UNIT	0.10	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149288	HAIR BUILDING FIRST FLOOR	ATTENDANCE OFFICE	IEC POWER LEAD	0.07	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149287	HAIR BUILDING FIRST FLOOR	ATTENDANCE OFFICE	SHURG EXTENSION LEAD	0.06	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149286	HAIR BUILDING FIRST FLOOR	ATTENDANCE OFFICE	MONITOR	0.11	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149285	HAIR BUILDING FIRST FLOOR	ATTENDANCE OFFICE	IEC POWER LEAD	0.08	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149284	HAIR BUILDING FIRST FLOOR	ATTENDANCE OFFICE	BASE UNIT	0.11	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149283	HAIR BUILDING FIRST FLOOR	ATTENDANCE OFFICE	IEC POWER LEAD	0.07	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149282	HAIR BUILDING FIRST FLOOR	ATTENDANCE OFFICE	SPLITTER	N/A	II				>19.99	08/03/2017	12 MONTHS	<0.10mA	I	F	
2149281	HAIR BUILDING FIRST FLOOR	ATTENDANCE OFFICE	CLASS 2 ADAPTOR	N/A	II				>19.99	08/03/2017	12 MONTHS	<0.10mA	I	F	
2149280	HAIR BUILDING GROUND FLOOR	STAFF ROOM	MONITOR	0.09	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149279	HAIR BUILDING GROUND FLOOR	STAFF ROOM	IEC POWER LEAD	0.06	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149278	HAIR BUILDING GROUND FLOOR	STAFF ROOM	BASE UNIT	0.09	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149277	HAIR BUILDING GROUND FLOOR	STAFF ROOM	IEC POWER LEAD	0.05	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149276	HAIR BUILDING GROUND FLOOR	STAFF ROOM	MONITOR	0.07	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149275	HAIR BUILDING GROUND FLOOR	STAFF ROOM	IEC POWER LEAD	0.05	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149274	HAIR BUILDING GROUND FLOOR	STAFF ROOM	BASE UNIT	0.08	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	
2149273	HAIR BUILDING GROUND FLOOR	STAFF ROOM	IEC POWER LEAD	0.05	I				>19.99	08/03/2017	12 MONTHS	<3.5mA	I	F	